


SR to YAMAHA G8/G9/G14/G16



- REPLACING STOCK CONTROLLER:
- * REMOVE BATTERIES AND CONTROLLER. CUT OFF WIRES FLUSH
 WITH FACEPLATE OF OLD CONTROLLER
 CRIMP 3/16' RING TERM ON YEL/BLK WIRE, CONNECT TO SCIENCID

- WITH RED/WHT WIRE.

 ** CRIMP 1/2' RING TERM ON GREEN WIRE, CONNECT TO B
 ** CUT OFF BROWN WIRE AND TAPE END OR HEATSRINK)

 ** CRIMP 1/4' FEMALE SPADE TO WIRES, CONNECT TO SR AS SHOWN
- * REMOVE RING TERMINAL FROM BLACK WIRE FROM SOLENIOD AND CRIMP 1/4' FEMAL SPADE AND CONNECT AS SHOWN
- * DRILL NEW MOUNTING HOLES IF NECESSARY
- * CONNECT LARGE WIRES TO CONTROLLER AS FOLLOWS:

 > A2 to M- <> B+ to B+ <> B- to B- </>
 > RECONNECT THROTTLE SENSOR PLUG AND PINK WIRE

 * ADD RESISTOR ACROSS SOLENOID (NOT INCLUDED)

 * ADD DIDDE ACROSS SOLENOID COIL (NOT INCLUDED)

REPLACING AXE CONTROLLER

* CRIMP 1/4" FEMALE SPADE TO GREEN WIRE, CONNECT TO CADD EXTENSTION IF NECESSARY)

* REPLACE SPADE ON BLUE WIRE WITH 1/2" RING TERM AND MOVE TO B-

ы

	\triangleleft
1N4001 1N5408 MR754	DIODE RATING
200A 400A	CONTACTOR RATING

DEM 200A 400A	CONTACTOR RATING
300A 300A 400A TR	CONTR RAT
7 400A 500A	ROLLER

4		
VOLTAGE	ANN400	ANN250
	450A	400A
IN SECTION		묾
RESISTOR RATING	MORE	LESS

FUSE

040 440 444	POWER RATI		•	❖
6AWG-4AWG 4AWG-2AWG 2AWG-1/0AWG	WER WIRE RATING	72V	367	VOLTAGE
300A 400A 500A	CONTROLLER RATING	1000 DHM 10W	250 DHM 10W	RATING

O	
Š	
SCALE	
DRAWING	

SR to	OPRIETARY SED, DISCLOSED ORIGINAL ORIGI	THIS TEMPLE, LAKY THIS TEMPLE, LAW, IN S. TEMPLE, LAW, IN S. TEMPLE, LAW, IN S. TEMPLE, LAW, INC., S. TEMPLE,	R. R.	032217)32217
	ĭ≺ſ	PROPRIETARY	R	033016	
033116	ឧ	ENGR D.Crockett	;	1000	- 1
6	033116	DRAWN R CSUK	APVD	JTAO	
		DWG SCALE: NIS		KEVIOIONO	7

REV.

* FUSES REQUIRED FOR ALL INSTALLATIONS

** DIDDE REQUIRED FOR ALL INSTALLATIONS

** KSI IS REQUIRED TO BE A SWITCHED INPUT, NOT RESISTIVE

** ASSUMES FOOTSWITCH IS OPEN WHEN THROTTLE OFF

** ASSUMES FOOTSWITCH IS OPEN WHEN THROTTLE OFF

** ALLTRAX RESERVES THE RIGHT TO CHANGE DIDCUMENTATION

**VITHOUT NOTICE

** ALLTRAX MAKES NO WARRANTY AS TO THE ACCURACY,

** SUFICIENCY, OR SUITABILITY OF ANY TECHNICAL

OR OTHER INFORMATION PROVIDED

SEE OPERATORS MANUAL FOR MORE INFORMATION

7	ALLTRAX
	1111 Cheney Creek Rd. Grants Pass, OR 97527 PHONE:(541) 476-3565
	Creek Rd. OR 97527 476-3565

T	~ ~ ⊢
	to
E DOCUMENT NO.	Yaho
Ö	Yahama G8, G9, Wiring Diagram
	G8, Diag
	G9, Iram
	G14, G16
REV.	G16

		TRAX INC	OR DISCLOSED	PROPRIETARY
FILEDM	\supset	3ZIS		SR
G-SR-		000		ç
-YAHAMA-G	S	SIZE DOCUMENT NO.	_	Yaha
8-69-6	DOC	ō	Wiring Diagram	∃ a
14-616-	DOC110-041		Diag	68,
WIRE-DI	041		ram	69,
FILEDWG-SR-YAHAMA-G8-G9-G14-G16-WIRE-DINSHEET 1of1				SR to Yahama G8, G9, G14, G16
1of1	В	REV.		G16